



STEEL FENCE POST

CURB STOP SHALL BE MUELLER #10300 MINNEAPOLIS PATTERN 1 1/4" STACK FOR USE WITH 1" CURB STOP AND SHALL INCLUDE STATIONARY ROD.

1" CURB BOX SHALL BE MUELLER H-15154 MINNEAPOLIS PATTERN OR APPROVED EQUAL. ALL STOPS SHALL BE FLARED FOR BOTH INLET & OUTLET.

CORPORATION STOP SHALL BE MUELLER CO. H-15000 OR APPROVED EQUAL WITH MUELLER THREAD FLARE TYPE JOINT.

MIN SLOPE 1/4" PER FT. (2.0%)

4" OR 6" PVC SDR 26 SEWER SERVICE PIPE.

**NOTE:**

ANY CURB STOP LOCATED IN BLACKTOP OR CONCRETE DRIVEWAY OR SIDEWALK SHALL BE COVERED WITH METER BOX COVER (FORD A-1) OR APPROVED EQUAL.

ALL WATER SERVICES SHALL BE 1" MIN. - TYPE K COPPER. ANY TAP LARGER THAN 1" SHALL USE A SMITH BLAIR STAINLESS STEEL SADDLE TYPE #317 OR #372 OR APPROVED EQUAL.

ANY NEW WATER SERVICE INSTALLED CONNECTING TO EXISTING WATERMAIN SHALL USE A STAINLESS STEEL SADDLE NO MATTER WHAT THE WATER SERVICE SIZE.

WATER SERVICE MUST BE CONTINUOUS WITH NO JOINTS UNLESS SERVICE IS OVER 100' LONG.

SANITARY AND WATER SERVICE LINES SHALL BE INSTALLED IN THE SAME TRENCH WITH 3 FEET OF SEPERATION.

EXCESSIVE SANITARY SEWER MAIN-LINE DEPTH MUST BE REVIEWED AND APPROVED BY THE ENGINEER.

SANITARY SEWER SERVICE RISER SHALL BE BACKFILLED AND COMPACTED WITH GRANULAR MATERIAL.



CITY OF EDINA  
ENGINEERING  
& PUBLIC  
WORKS  
DEPTS.

SEWER AND WATER SERVICE  
CONNECTION W/ RISER

*Wayne A. Kule*  
APPROVED: CITY ENGINEER

REVISED:  
01-08  
STANDARD  
PLATE  
301